

Branched KDHE Chris Seeds

Helen Holm 2.17.26

@ 9:45am

CITIZEN REQUEST FORM CALLOUT/WORK DONE

Copy 

DATE REC'D: 2/17/2026 TIME REC'D: 8:22 A.M. P.M.

AFTER HOURS? YES NO

CALLER'S NAME: Scott Stanley KDHE REPORT YES BY WHOM T. Awardado

TRANSPARENCY REPORT (IF CLI THAT REACHED STORM DRAIN): YES

NAME OF CITIZEN NEEDING ACTION (IF DIFFERENT FROM CALLER): _____

HOME PHONE: 913-547-2742 WORK PHONE: _____

ADDRESS: 1601 Ottawa St

NATURE OF REQUEST: Sewer smell behind property. Saw over the creek water or sewer pouring into creek.

INITIAL RESPONSE

DATE PROVIDED: 2/17/26 TIME PROVIDED: START: 8:30 FINISH: 2:55pm

ACTION TAKEN: Arrived at the above address went to creek behind address and notice gray water in creek found and opened MH #0812 was holding water we then had to rod from MH #0700 due to 0812, 0811, 0702 not holding water. Rod main 402 ft broke thru package, water started drain. After MH 0812, 0811, 0702 were no longer full (standing) water, we started drain washing down creek. While pumping gray water back into 0812, found where it was coming into creek. pipe on W drive under the above address.

UPSTREAM MANHOLE: 0702, 0701 DOWNSTREAM MANHOLE: 0701, 0700

ROD FLUSH _____ FROM MANHOLE TO MANHOLE: YES _____ NO

TOTAL FEET LINES CLEANED: 402 ft

VEHICLE 1: 361 START MILEAGE: _____ END MILEAGE: 44538
VEHICLE 2: 074 START MILEAGE: _____ END MILEAGE: 9982
VEHICLE 3: _____ START MILEAGE: _____ END MILEAGE: _____

CREW: WPC SIGNATURES: [Signature]

HOW CONTACTED:

TELEPHONE FACE TO FACE (ON SITE) BY WHOM? _____

PICTURES TAKEN? YES _____ NO _____ BY WHOM? _____

FURTHER ACTION REQUIRED: YES NO

IF YES, WAS A WORK ORDER TURNED IN TO ASST. SUPERINTENDENT: yes

COMMENTS: Overflow 500 - 800 gals

Incident Location: (check all that apply)

- | | |
|--|---|
| <input type="checkbox"/> Plant | <input type="checkbox"/> Private Sewer Line |
| <input type="checkbox"/> Lift/Pump Station | <input type="checkbox"/> Basement |
| <input type="checkbox"/> Manhole(s) | <input checked="" type="checkbox"/> Other (specify below) |
| <input type="checkbox"/> City Collection Line (Line Break / Joint) | |

Cause of Incident:

- | | |
|---|--|
| <input type="checkbox"/> Intentional Bypass for Repair/Construction | <input type="checkbox"/> Equipment Failure |
| <input type="checkbox"/> Excessive Rainfall, Snow Melt | <input type="checkbox"/> Control System Failure |
| <input type="checkbox"/> Unplanned Construction Related Break | <input type="checkbox"/> Power Related Failure |
| <input type="checkbox"/> City Line Break (Not Construction Related) | <input type="checkbox"/> Operations Related Failure |
| <input checked="" type="checkbox"/> City Line Blockage | <input type="checkbox"/> Maintenance Related Failure |
| <input type="checkbox"/> Private Line Break | <input type="checkbox"/> Vandalism |
| <input type="checkbox"/> Private Line Blockage | <input checked="" type="checkbox"/> Other |

BOW - Incident Report

version 1.7

(Submission #: HQK-GNQG-HVZFK, version 1)

Details

Submission Alias Wastewater Incident Report

Submission ID HQK-GNQG-HVZFK

Status In Process

Form Input

Permit Information

Please confirm the permit and facility information shown here are correct before submitting this form.

Permit Number:
KS0036366

Effective Date
03/01/2023

Expiration Date
02/28/2028

Facility Name
LEAVENWORTH, CITY OF (WWTP)

Facility Location
1800 S 2ND STREET
LEAVENWORTH, KS 66048

Incident Information

Type of Incident
Bypass

KDHE Contact Person
Chris Seeds/ Helen Holm

KDHE Contact Date
02/17/2026

KDHE Contact Time

09:45 am

Date Incident Discovered

02/17/2026

Time Incident Discovered

08:30 am

Date Incident Ended

02/17/2026

Time Incident Ended

10:30 am

Total estimated gallons bypassed, spilled, or routed through failed equipment for all locations on this form

800

If rainfall induced event, approximate inches of rainfall

NONE PROVIDED

Are multiple locations listed due to rain event?

No

Incident Location

Manhole(s)

Identify ALL Incident Locations by Name, Street Address or Manhole Number as appropriate

1601 Ottawa st out of manhole 0702

Cause and Corrective Action**Cause of Incident**

City Line Blockage

Additional explanation of reason for incident

city staff believe roots have collected debris and blocked the line

Corrective action taken (if any)

city staff cleared blockage and has CCTV'd line. found roots to be in line. we Have scheduled this on our root treatment list with Dukes. they should be here in the next few months to root treat main.

Attachments

NONE PROVIDED

Comment

NONE PROVIDED

Status History

	User	Processing Status
2/20/2026 12:28:45 PM	Tim Guardado	Draft
2/20/2026 12:43:26 PM	Tim Guardado	Submitting
2/20/2026 12:43:31 PM	Tim Guardado	Submitted
2/20/2026 12:43:32 PM	Tim Guardado	In Process

